ON-SITE WASTEWATER SECTION

COUNTY: IREDELL

4726 709215 PART of

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DAVID PERRY APPLICANT: SAME

ADDRESS: 332 York Spann Road, Mooresville APPLICATION DATE: _____ DATE EVALUATED: 1-30-99

PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.52± Acre

LOCATION OF SITE: FAWNWOOD I #5 PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	L 4%	0-10	MMGR / SL	VFR / NEXP	—	—	—	—	PS 0.25
		10-48	WFABK / C	FI-S/P / NEXP					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE

SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HEDRICK

OTHER(S) PRESENT: JIM NELSON, DAVID PERRY