DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4726 70 9215 (PT)
COUNTY: [redacted]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DAVID PERRY — APPLICANT: SAME
ADDRESS: 332 YORK SPANN RD, HAYDENVILLE — APPLICATION DATE: 12-1-99 — DATE EVALUATED: 12-14-99
PROPOSED FACILITY: 3BRH W/S — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 0.721 ACRE
LOCATION OF SITE: FAWNWOOD #11 — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	R 1%	0-26	SBK / C	FR S/P / NEXP					PS 0.3
		26-98	SBK / CL	FR SS/SP / NEXP					
2	SS 2%	0-24	SBK / C	FR S/P / NEXP					PS 0.3
		24-98	SBK / CL	FR SS/SP / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: DAVID PERRY