DEPARTMENT OF ENVIRONMENT, HEALTH & [illegible]
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: (REDELL
4726 709215 PART OF

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: STANDARD BUILDING Co. APPLICANT: JIM NELSON
ADDRESS: 202 HARRIS BRIDGE RD, S.P, NC APPLICATION DATE: ____ DATE EVALUATED: 1-30-99
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.52 ACRE
LOCATION OF SITE: FAWNWOOD I #9 PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

| PROFILE # | .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFIL CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | L 4% | 0-10 | MMGR / SL | VFR / NEXP | — | — | — | — | PS 0.25 |
| | | 10-48 | WFABK / C | FI-S/P / NEXP | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 2 | L 6% | 0-8 | MMGR / SL | VFR / NEXP | — | — | — | — | PS 0.3 |
| | | 8-16 | WFABK / C | FI-S/P / NEXP | | | | | |
| | | 16-48 | MMSBK / C | FR / NEXP | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 3 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 4 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | S | PS |
| System Type(s) | III | III |
| Site LTAR | 0.3 | 0.25 |

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: JIM NELSON, DAVID ARRY