44453

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15040

OWNER OR CONTRACTOR Austin & Austin Builders DATE 11/19/92 PERMIT NO. 92-9-A-25

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR Monticello Drive, TL Miller Farm Road, TL Doe Trail, Lot on (L) in Curve S.R. No. _____

SUBDIVISION NAME Deercroft LOT NO. 25 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area Ample

Soil Characteristics PS


Application Rate 0.35 GPD / FT2

Topography 4-6% LINEAR

Depth to Water Table > 4'

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

TP 9/7/92

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑

Installed by Austin & Austin Builders

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Steve Hedrick

COMMENTS _____

Repair Area is 100% Conventional, Gravity Fed.

CERTIFICATE OF COMPLETION BY Steve Hedrick DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold