DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Perry APPLICANT: David Perry
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 3BR/Conv PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: (Y)
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ (0.56 Acre)
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Fawnwood Lot # 10

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear	0-23	C		23" BRM/Com mottles				CLS
		23-34	C/SC		34" Chroma 2				
		34	SC/Sap		36" Chroma 1				
2	6% Linear	0-36	C Abk	SP SEXP					PS .25
		36-48	SC/Sap	SS SP SEXP					
3	7% Linear	0-3	SC G	NS NP NEXP Mica BRK					PS .25
		3-35	SC Abk	SP SSXP					
		35-48	SCL/Sap Saprolite	SS SP SEXP					
4	6% Linear	0-34	C Abk	SP SEXP					PS .25
		34-48	SC/Sap	SS SP SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pump 25% Red	Pump 50% Red Area
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____