DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: REDELL
4726 82 3288(P)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: SAMUEL SCOTT APPLICANT: SAME
ADDRESS: 2278 S. CHIPLEY FRD SNOW, 28625 APPLICATION DATE: _____ DATE EVALUATED: 9-1-99
PROPOSED FACILITY: 3BR/1½0.5 PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 15,000 SF
LOCATION OF SITE: CROSS CREEK II #35 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 1-1.5%	0-6	GR / SL	VFR / NEXP					PS 0.33
		6-15	SBK / SCL	FR / NEXP					
		15-48	SBK / CL	FR / NEXP					
2	L 1%	0-8	GR / SL	VFR / NEXP					PS 0.33
		8-16	SBK / SCL	FR / NEXP					
		16-48	SBK / CL	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	I	III
Site LTAR	0.33	0.33

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: PETE SCOTT, DAVID YOUNG