IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Scott Mckinney DATE 12/6/88 PERMIT NO. 010

PHONE: Business _____ Home _____

LOCATION 115N TL Scotts Creek L Ethel R DJ IN 200 yards on Right

S. R. No. _____

SUBDIVISION NAME WOODROSE PARK. LOT NO. 67 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil good Suitable
Percolation Rate 14
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 1.25 ac

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 210 Linear Ft. 210
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off downspouts away from septic tank system & create surface water diversion trench above septic tank system.

CERTIFICATE OF COMPLETION BY Steve Brown & Darren Weaver DATE 12-6-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold