PARTMENT OF ENVIRONMENT,
ALTH, & NATURAL RESOURCES
ISION OF ENVIRONMENTAL HEALTH

SHEET___OF___
PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: Sunwood Builders OWNER: AGENT: PHONE:
DRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
CATION OF SITE:
TER SUPPLY: On-Site Well___Comm. Well___Public___Other___ EVAL. METHOD: Auger Boring___Pit___Cut___

ROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 10%	0 to 48"	C SbK	SEAP SS SP	PS	N/A	PS	N/A	.3
2	Linear 10%	0 to 48"	C SbK	SEAP SS SP	PS	N/A	PS	N/A	.3
3	Linear 15%	0 to 12"	Clay SbK	SEAP SS SP	PS	Rock 12"	U	U	.1
		12 to 60	Rock + Saprolite						
4	Linear 20%	0 to 8	Clay SbK	SEAP SS SP	PS	Rock 8"	U	U	.1
		8 to 58	Rock Saprolite						
5	Linear 8%	0 to 8	clay	SEAP SS SP	PS	N/A	PS	PS	.3
		8 to 48	CL	SEAP SS SP					

AILABLE SPACE (1945) Yes SITE CLASSIFICATION (1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
ALUATED BY: J.C. Moore OTHER(S) PRESENT:
MMENTS: + Soil Scientist Paul Pennington
Tony Jacobs + Associates