DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Samuel Scott APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 3BR/Cabin PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .34
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Crossrock Lot #15

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	5% Linear	0-6	SL g	NS NP NE Rd					PS .3
		6-28	CL SBK	FrVFi SS SP SEPP					
		28-44	CL Sm Pl Lo Bk	Fr SS SP SEPP					
		44-48	CL Sap Saprolite	Fr SS SP SEPP					
2	Linear 6%	0-4	SL g	NS NP NE Rd					PS .3
		4-30	CL SBK	FrVFi SS SP SEPP					
		30-42	CL Sm Pl	FrFi SS SP SEPP					
		42-48	CL Sap/Sap	Fr SS SP SEPP					
3	Linear 5%	0-3	SL	NS NP NE Rd					PS .3
		3-27	CL SBK	SS SP SEPP					
		27-48	CL Sap/Sap	SS SP SEPP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. 25% Red	50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____