IREDELL COUNTY HEALTH DEPARTMENT 38994

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12307
OWNER OR CONTRACTOR RICHARD CRANDALL DATE 3/25/91 PERMIT NO. 9AB-A-24

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL SCOTTS CREEK ROAD, TL BROOKHOLLOW DR, TR HOLLOWBROOK CT, 1ST LOT ON (R) S. R. No. _____

SUBDIVISION NAME BROOK HOLLOW EST. LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil PS
Percolation Rate .4 6PD / FT2
Topography 2-4% LS
Depth to Water Table 4'
Rock or other impervious formations NONE

Lot Area AMPLE


_____ Basement with Plumbing 31' X 80' Basement without Plumbing ✓ No Basement

ACP 1/28/91

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by STEVE JORDAN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEARICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEARICK DATE 3/25/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold