44787

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15135
OWNER OR CONTRACTOR J. L. HOPE DATE 1/20/93 PERMIT NO. 9A-8-A-11

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL SCOTTS CREEK ROAD, TR BOWMAN ROAD, 11TH LOT ON (L) S.R. No. _____

SUBDIVISION NAME BROOKHOLLOW ESTATES LOT NO. 11 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑
Auto. Dishwasher Yes ☑ No ☐
Auto. Wash. Machine Yes ☑ No ☐
Lot Area AMPLE

Soil Characteristics PS
Application Rate 0.40 GPD / FT²
Topography 8-10% LINEAR
Depth to Water Table >4'
Rock or other impervious formations NONE NOTED

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space

ACP 9/20/92
Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ☐
Public ☑



Plot of System (Not to Scale)

Installed by ARNIE DUNCAN

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL, PARTIAL-PUMP, PARTIAL-GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 1/20/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold