IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 40982
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13328

OWNER OR CONTRACTOR LEONARD LAZENBY DATE 11/6/91 PERMIT NO. 9A-7-A-26

PHONE: Business _____ Home _____

LOCATION NC 115N, TL SCOTTS CREEK RD (SR 1551), TL ETHEL LANE, LOT ON (R) NEAR ENA S. R. No. _____

SUBDIVISION NAME ROSEWOOD PARK LOT NO. 26 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.35 GPD / FT²	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8% HS	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	54"	
			Rock or other impervious formations	NONE	

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

TP 9/16/91



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by HARRY REEP

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: STEVE HEDRICK DATE 11/6/91

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold