06253

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR PERRY JENKINS DATE 5-15-87 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115 N - T.L. on Sullivan Farm Rd. - cross old 115 H.T.L. on Old Bond House down on left. S. R. No.

SUBDIVISION NAME WOODROSE PARK LOT NO. 576 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Ample

Character & Porosity of Soil Prov. Suitable.


Percolation Rate 14 min/in.

Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations none observed.

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12

Water Supply: Individual ( )

Public (✓)

Installed by Eddie Younts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-15-87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold