IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR: Samuel Scott DATE 12/9/87 PERMIT NO.

PHONE: Business Home

LOCATION Scotts Creek off 115, Lf on Ethel, Rt on 21, Rt on Friendly Hse on Lf S. R. No.

SUBDIVISION NAME Woodrose Park LOT NO. 70 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area Ample

Character & Porosity of Soil Prov Suitable
Percolation Rate 0.4 spd/ft²
Topography 2-6%
Depth to Water Table 10 ft
Rock or other impervious formations None Noted

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by David Yountz

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown RS

COMMENTS: Good Installation!

CERTIFICATE OF COMPLETION BY [signature] DATE 12/30/87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold