DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: 4726928189
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: KENNETH A WATT APPLICANT: SAME
ADDRESS: 129 BECKHAM RD, STVL, NC 28625 APPLICATION DATE: 9-16-99 DATE EVALUATED: 10-4-99
PROPOSED FACILITY: 3BR H 4/5 PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 22,179.59 SF
LOCATION OF SITE: WOODROSE PARK #1 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFIL. CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	L 4%	0-48	SBK / c cL	FR / NEXP					PS 0.3
2	L 4%	0 48	SBK / c cL	FR / NEXP					PS 0.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HENDRICK
OTHER(S) PRESENT: KENNETH WATT