IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kermit Howard Hedrick DATE 5-1-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. Cross 4th Creek T.L. on Rd # 1553 Go approx 1 Mile T.R. in drive. House at end of Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Acreage

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Slope
Depth to Water Table Low
Rock or other impervious formations Some Shale rock in bottom



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5-1-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold