DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Richard Bollesup
ADDRESS: 126 Tree bark Rd.
PROPOSED FACILITY: Conv. Store 2 Gmp PROPOSED DESIGN FLOW (.1949): 1000 gpd
LOCATION OF SITE: 3029 Willesboro Hwy
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 10-2-13
DATE EVALUATED: 10-17-13
PROPERTY SIZE: 3.0 acres
PROPERTY RECORDED: YES
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2-3%	0-28	Fill						.25
		28-59	RC ABK	FI SSSPSSHP					
		59-66	RCL WABK	FR SSSPSSHP	Mica Incl.				
2	L 2-3%	0-28	Fill						.25
		28-54	RC ABK	FI SSSP MD SE					
		54-70	RCL WABK	FR Mod SE					
3	L 2-3%	0-19	FILL						.25
		19-56	RC ABK	FI SSSP SE					
		56-65	RCL WABK	FR SSSP SHP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):

EVALUATED BY:
OTHER(S) PRESENT:

COMMENTS: