## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L.G. Lackey DATE 11/15/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy. 115 N. Past O.C. Gregory store. House on Rt. at Rd # 1908 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area 235 X 130

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography Slope to road
Depth to Water Table Low
Rock or other impervious formations None




Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1350 Linear Ft. 400
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public ( )

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Surface Water & downspouts to be diverted away from septic Tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/15/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold