IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Keller DATE Aug 23, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N T.R. on SR. 1958 T.L. on SR. 1962 2nd trailer on Lt. Back off Rd. ~250' S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	—
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Flat
Site Suitable	Yes (✓) ?	No ( )	Depth to Water Table	unk
			Rock or other impervious formations	none obs.

Lot Area 20,000 ft²



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 210
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public ( )

Installed by Ronald Lackey

IMPROVEMENTS PERMIT BY E.A. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Mark R. Hinson DATE Aug 23 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold