DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: IREDELL
9727 660989 (PT)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JASON SPRINKLE APPLICANT: SAME
ADDRESS: 139 YADKIN VALLEY RD, STVL APPLICATION DATE: 12-20-99 DATE EVALUATED: 1-10-99
PROPOSED FACILITY: 3BR D/W PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE:
LOCATION OF SITE: NC 115 N, TR YADKIN VALLEY RD, 0.1 MILE ON LFT PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 4%	0-9"	GR / SC	FR / NEXP	WATER SEEPING INTO AUGER HOLE @ 8"	S	S	S	PS 0.3
		9-48"	SPK / C	FI 3% / NEXP					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HADDOCK
OTHER(S) PRESENT: LARRY, JASON, WES & DAVID SPRINKLE