Millin Barn
Bldg.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frankie Stikeleather DATE 9/28/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N - Just Past Gregory Store T.R. on Rd #1904. Go appox ½ Mile House on L.

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. N. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit: Yes ( ) No (✓)
Auto. Dishwasher: Yes (✓) No ( )
Auto. Wash. Machine: Yes (✓) No ( )
Sole Surplus: Yes (✓) No ( )

Lot Area 20,000 sq ft +

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slight Slope to front
Depth to Water Table Low
Rock or other impervious formations None Noted



Plot of System RA 1909

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
Water from Lewis Stikeleather House

Installed by _____

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS. _____ The proposed Garage addition does not appear to impact the existing septic system.

**NOTE: _____

Date 9-6-10 R.S.
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

JAN. 6, 1989 24:29