IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date Dec. 29 1945

Owner H. W. WAFT Address R. 2 STATESVILLE

Tenant SAME Address _____

Installed by HARVEY HAGER Address R. 2 STATESVILLE

Location of Property 7 MI. OUT 115 ON LEFT THIS SIDE OF TRINITY CHURCH

Kind of Tank CONC. Capacity 500 Length of trench 210'


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 1-25 1946 Approved (✓) Disapproved ( )

Remarks: _____

First five feet of line from outlet should be of cast iron soil pipe.



Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.