IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby L. Bunton DATE 3-2-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 - House on Rt. Just before Rd # 1960.

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil _____
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate _____
Auto. Wash. Machine	Yes (✓)	No ( )	Topography _____
Site Suitable	Yes (✓)	No ( )	Depth to Water Table _____
			Rock or other impervious formations _____

Lot Area 1 acre

Existing System



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by Herman Hixson in 1972

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Trailer to be moved when house is completed. Septic Tank system working O.K. at this time.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-2-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold