HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10E-A-96
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: WAYNE JOHNSTON OWNER: ✓ AGENT: PHONE: 876-6731
ADDRESS: RT. 11, Box 386-C APPLICATION DATE: 5/24/94 DATE EVALUATED: 5/24/94
STVL, NC 28677 PROPOSED FACILITY: 3 BR MODULAR HOME
PROPERTY SIZE: ~150 x 262
LOCATION OF SITE: NC115N, TR BRANCHWOOD RD, ON (R) ~ 1.0 MILE
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-48	C	ABK	1:1 / FI	.1942 WETNESS CONDITION 5
						.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 - GPD/FT²
2	L 4%	0-48	C	ABK	1:1 / FI	.1942 WETNESS CONDITION 5
						.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 - GPD / FT²
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: WAYNE JOHNSTON
COMMENTS:

DRAFT