03755

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth L. Holmes DATE 12-11-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N - TL on SR 1553 - TR on SR 1560 Cane Creek Rd
Double wide on Rt past Deaton's Stone Church S. R. No. 1560


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3	No. Bathrooms 3			Character & Porosity of Soil	Party Suitable
Garbage Disposal Unit	Yes ( )	No (✓)		Percolation Rate	45 avg 60 max
Auto. Dishwasher	Yes ( )	No (✓)		Topography	2 to 6%
Auto. Wash. Machine	Yes (✓)	No ( )		Depth to Water Table	10'
Site Suitable	Yes (✓)	No ( )		Rock or other impervious formations	none

Lot Area .46d

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 24

Water Supply: Individual (✓)
Public ( )

Installed by Kenneth Keffer

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox DATE 12/11/85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold