45400

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15362

OWNER OR CONTRACTOR JEFFREY B. STEELE DATE 1/19/93 PERMIT NO. 14B-2-A-2

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL PISGAH ROAD, TL TREEBARK ROAD, ~0.6 MILE ON (R) S.R. No. _____

SUBDIVISION NAME WATSON FARMS LOT NO. 2 SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ D/W Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 1.5 AC

Soil Characteristics PS


Application Rate 0.35 GPD/FT²

Topography 2-4% LINEAR

Depth to Water Table >4'

Rock or other impervious formations NONE NOTED

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

TP 8/20/92

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual ☑ WELL

Public ☐

Installed by ANDY JONES

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL, GRAVITY-FED.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 1/19/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold