DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ____
COUNTY: 103998

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4728-07-3798.
4728-07-4968

OWNER: Tim Alexander APPLICANT: Same
ADDRESS: 302 TREEBARK RD, STVC, 28625 APPLICATION DATE: 12-13-01 DATE EVALUATED: 1-19-02
PROPOSED FACILITY: FUTURE 3BR PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3.513 AC
LOCATION OF SITE: HARRINGTON EST + 85 79 PROPERTY RECORDED: ____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	L 10%	0-30	SBK C	FR SS/SP SE/P					PS 0.3
		30-48	SBK SiC	FR SS/SP					
2	L 12%	0-34	SBK C	FR SS/SP SE/P					PS 0.3
		34-48	SBK SiC	FR SS/SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Bodick
OTHER(S) PRESENT: Tim Alexander & Son