02707 - Permit originally issued under name of Randy Bridges & Don McClelland

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR MARIE ELMORE DATE 7-1-87. PERMIT NO.

PHONE: Business Home

LOCATION Hwy 115N - cross S. Yadkin River - ½ mi. on (R).

S. R.

SUBDIVISION NAME LOT NO. #2 SECTION OR BLOCK NO. list on plat.


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Ample

Character & Porosity of Soil Prev. Suitable.
Percolation Rate 2-6, 6-11"
Topography
Depth to Water Table 10'+
Rock or other impervious formations scattered rock.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 3
No. of Lines
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-1-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold