HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED: 14B-A-63
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JAMES S. ELMORE OWNER: ✓ AGENT: PHONE: 873-9830
ADDRESS: 161 N. MULBERRY ST APPLICATION DATE: 5-25-95 DATE EVALUATED: 8-2-95
STATESVILLE, NC. 28677 PROPOSED FACILITY: 3BR S/W MH
PROPERTY SIZE: 1.92 ACRE
LOCATION OF SITE: NC 115 N, CROSS S. YADKIN RIVER, 0.25 MILE ON (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring Pit ✓ Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 5%	0-12	C	WSBK	1:1/ FI	.1942 WETNES CONDITION S.
		12-36	CL SAPROLITE	SS/ SP		.1943/.1956 SAPROLITE PS.
		36+	SL SAPROLITE	SS/ NP		.1944 RESTRICTIVE HORIZON S.
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 GPD/FT2
2						1942 WETNES CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) LIMITED SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE PRESSURE-PD PBPS (TYPE II)
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JACK MOORE, HERMAN GIBSON, BRAD STALLARD
COMMENTS: TYPE II CHAMBERED SYSTEM MAY BE USED FOR 2BR MH

DRAFT

0002209