08802

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Chris Robertson DATE 5-20-88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N of I-40 on Farm House Rd (just before S. Yadkin River) Use 1st Stop Sign - Tel. - 2nd house on (L) S. H. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 1 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Appears Suitable.	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	30 min/in.	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'	
			Rock or other impervious formations	scattered rock	

Lot Area 100' x 300'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 375 Linear Ft. 125
Depth of Stone in Lines 12" + 12"

Water Supply: Individual (✓)
Public ( )

Installed by Miller & Sons Backhoe.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Ellen Fagg, Kelly Sheets & Darren Weaver.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brewer DATE 6-20-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold