DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Oakwood Homes — APPLICANT: Same
ADDRESS: 1642 Charlotte Hwy Troutman NC — APPLICATION DATE: 1/31/01 — DATE EVALUATED: _____
PROPOSED FACILITY: 38R mH — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: 3.9 Ac.
LOCATION OF SITE: Hwy 115N (R) crawl Cutlaw, bear (R) at Cas. on (R) — PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	14% Linear	0-10	scl	Fr SS SP SEH					PS .3
		10-33	cl	Fi SP					
		33-48	cl w/ few scl	Fr SS SP SEH					
2	15% Linear	0-8	scl	Fr SS SP SEH					PS .3
		8-26	cl	Fi SP SEH					
		26-41	cl w/ few scl	Fi SS SP SEH					
		41"	scl						
3	Linear	0-7	scl w/ few SBK	Fr SS SP SEH					PS .35
		7-26	cl w/ few SBK	Fi SP SEH					
		26-40	cl w/ few scl w/ few SBK	Fi SP SEH					
		40-48	cl w/ few scl w/ few SBK	Fr SS SP SEH					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Availble Space (.1945)	PS	PS
System Type(s)		
Site LTAR	.3	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Wilbur Johnson
OTHER(S) PRESENT: Jake Patmon