HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED: 9P-A-62
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MICHAEL LYNN HOOPER SR. OWNER ✓ AGENT: PHONE: 876-3332
ADDRESS: 162 CRIDER RD. APPLICATION DATE: 6-26-95 DATE EVALUATED: 7/3/95
STL, NC 28677 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 6.3 AC.
LOCATION OF SITE: NC 115 N, TR CRIDER, TR @ YIELD, TR PRIVATE DRIVE @ BOX #162
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6-8%	0-3	SCL	GR	1:1/ VFR	1942 WETNES CONDITION S
		3-38	C V/MCA	WSBK	1:1/ FR	1943/ 1956 SAPROLITE PS - MIX @ 38"
		38-98	SAPROLITE	MIX V/ CLAY		1944 RESTRICTIVE HORIZON S
						1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 GPD/FT
2						.1942 WETNES CONDITION -
						.1943/ 1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) 5" SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S HEDRICK OTHER(S) PRESENT: BRADY FREEMAN, EUGENA HOOPER & FATHER
COMMENTS:

DRAFT

000735