DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: CRAVEN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4728554482

OWNER: MARY DALTON APPLICANT: SAME
ADDRESS: BAILEY FARM ROAD, SIVC APPLICATION DATE: 1-7-02 DATE EVALUATED: 2-9-02
PROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 9.52 ACRES
LOCATION OF SITE: NC 11 SN, TR BAILEY FARM RD, 0.7 mi SNR PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ ~~Auger~~ Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 10%		WILKES SOILS - EVEAL			LOCATIONS 4			4
2	SLIGHT N 6%	0-20	SBK C	FI SS/P SEXP					PS 0.25
		20-48	SBK SiC	FR SS/SP SEXP					
3	SLIGHT N 8%	0-26	SBK C	FI SS/P SEXP					PS 0.25
		26-48	SBK SiC	FR SS/SP SEXP					
4	SLIGHT N 8%	0-24	SBK C	FI SS/P SEXP					PS 0.25
		24-48	SBK SiC	FR SS/SP SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): AS
EVALUATED BY: S. HODNICK
OTHER(S) PRESENT: DERRICK DALTON