IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Daniel A. Ruder DATE 23 July 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 115 N. Cross Roads Lot 8 Rd # 1905 on Rgt. Approx .9 mi Home on Rgt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 plus


Character & Porosity of Soil Red Clay Loam

Percolation Rate 60

Topography Slope Rear of property

Depth to Water Table nil

Rock or other impervious formations nil



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Vada Looby

IMPROVEMENTS PERMIT BY _____

COMMENTS: Map at file prob bed & large Grad. Mr Ballentine gave permission to run Cross Lines on his property.

CERTIFICATE OF COMPLETION BY W M Ballentine DATE 23 July 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold