DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: _____
COUNTY: GRANVILLE

4728 80 8134

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ERNEST RUNGE APPLICANT: SAME
ADDRESS: 374 LONG ISLAND RD, STVL APPLICATION DATE: 1-21-99 DATE EVALUATED: 2-4-99
PROPOSED FACILITY: 3BR DW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.736 Ac
LOCATION OF SITE: RIDGECREST # 57 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 9%	0-12	SBK / C	FR-SS/SP/SEXP	—	—	—	—	PS 0.3
		12-30	SBK / C	FR / SEXP					
		30-46	SBK / SiC	FR / SEXP					
2	L 5%	0-12	SBK / C	FR SSP / SEXP	—	—	—	—	PS 0.3
		12-98	SBK / C	FR-SS/SP/SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: J.C POPE