IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Warren DATE 12-31-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. Just Past Snow Creek T.L. on Road # 1572. Go Approx 1 Mile Trailer on R. in Curve S. R. No. 1572


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	[redacted] Sandy Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	No Perk Test	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Sloping to Back Lot.	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
			Rock or other impervious formations	Some Rock in bottom of Ditch	

Lot Area 150 X 200



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Hit Rock in bottom of ditch. However due to Good Soil I feel this job will be adequate for this One Trailer

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 1-30-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold