07330

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TRITON FINANCIAL LTD. DATE 9-2-87. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 - cross Snow Creek Rd. - 1/2 mi. on left - enter dev. then left at 1st st. - lot on ⓒ at curve. S. R. No. _____

SUBDIVISION NAME COUNTRY LIFE ESTATES. LOT NO. 49 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1-2 Character & Porosity of Soil Drew. Suitable.

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 4 min/1 in.


Auto. Dishwasher Yes ( ) No (✓) Topography 2-6% slope

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 18+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed.

Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Dennis Hallifax

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Don't drive or park over S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 9-2-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold