DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4729-05-3880.
COUNTY: [redacted]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DONNIE ESTES APPLICANT: SAME
ADDRESS: 3941 WILKESBORO HWY STVL APPLICATION DATE: 4-2-02 DATE EVALUATED: 5-2-02
PROPOSED FACILITY: 3BR SW MH PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: 2.0 ACRES
LOCATION OF SITE: POND RUN LANE, ENDS ON RIGHT PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 6%	0-48	ABK SBK MICACEOUS C	FI S/P SE/SP					PS 0.25
2	SLIGHT H 8%	0-48	ABK SBK MICACEOUS C	FI S/P SE/SP					PS 0.25
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	I	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HODGES
OTHER(S) PRESENT: RAY RENDL, DONNIE ESTES