IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

11660

OWNER OR CONTRACTOR HENRY WIDMER DATE 9/4/90 PERMIT NO. 14-4-A-19

PHONE: Business _____ Home _____

LOCATION NC 115 N, R on PAVED S. 5 mi BEFORE CEMPER SCHOOL
150 yds on (R) S. R. No. _____

SUBDIVISION NAME JOHN S. KING EST. LOT NO. 19 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil PS
Percolation Rate 4
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement STP



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

WELL ⊗

Installed by DENNIS GALLAGHER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

TO NC 115 →

IMPROVEMENTS PERMIT BY STEVE BROWN

COMMENTS: KEEP WELL 50' MINIMUM FROM SYSTEM

CERTIFICATE OF COMPLETION BY STEVE HANCOCK / GLENN FOX, JR DATE 9/5/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold