IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lenny Mason DATE May 26, '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N x Snow Creek T.L. on 2nd dirt rd. to left 200' on left S. R. No. _____

SUBDIVISION NAME Kingsdale Trailer Pk. LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 Ac.


Character & Porosity of Soil Appling clay loam

Percolation Rate _____

Topography 2-6%

Depth to Water Table 7+'

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 765 Linear Ft. 255

Depth of Stone in Lines 16"+

Water Supply: Individual ( )

Public (✓)

Installed by Owner Alexander

IMPROVEMENTS PERMIT BY W. R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wm R. Henson DATE May 26, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold