08110

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 3-30-88 PERMIT NO. _____

OWNER OR CONTRACTOR ROGER NORTON Home _____

PHONE: Business _____

LOCATION Hwy 115N - cross Beaver Creek - go approx 1/2 mi. after dev. on left - T.L. on 1st st - 1st T.L. on 1st st - 1st T.L. on left - 1st Lot on cul-de-sac No. _____

SUBDIVISION NAME COUNTRY LIFE ESTATES LOT NO. 46 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Ample

Character & Porosity of Soil Sandy Loam Suitable

Percolation Rate Good 10 Min

Topography Level to Slight Slope

Depth to Water Table Not observed.

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:


No. of Lines 2

Sq. Ft. 720 Lineal Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)




Plot of System

Installed by Dennis Hallisey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL [illegible]

Permit is VOID if any unauthorized changes are made in installation of system and/or if any [illegible] Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: [illegible]