DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of _
PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM


4729-16-4129

OWNER: MICHAEL T. UPRIGHT APPLICANT: SAME
ADDRESS: 170 CEDAR RIDGE, STVL 28625 APPLICATION DATE: 3-25-04 DATE EVALUATED: 5-6-04
PROPOSED FACILITY: 3BR D/W PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.4 ACRE
LOCATION OF SITE: NC 115 N, TR OLD TIMER DR, LEFT AFTER CURVE PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 8%	0-3	GR SL	VFR SSPP					PS 0.25
		3-40	ABK/SBK C	FI S/SP SSPP					
		40-48	SBK MICACEOUS CL	FR SSPP					
2	L 10%	0-4	GR CL	VFR SSPP					PS 0.25
		4-48	ABK/SBK C	FI S/SP SSPP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	IV
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: JENNIFER UPRIGHT


OLD TIMER DR
WELL
1
2