DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 14F-A-66
PROPERTY RECORDED:
COUNTY: IREDELL

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: CLARENCE T. COMER OWNER: ✓ AGENT: PHONE: 876-0845
ADDRESS: 3650 WILKESBRO HWY APPLICATION DATE: 3/15/95 DATE EVALUATED: 3/22/95
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE W/ BASEMENT
PROPERTY SIZE: 3.52 ACRES
LOCATION OF SITE: NC 115 N, ON (R) AT FORD FARM ROAD (SR 1909)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | L 14% | 0-20 | SBK / C | 1:1 / FI | S | S | PS | — | 0.30 |
| | | 20-48 | WSBK / SIC | 1:1 / FR | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 2 | L 10% | 0-29 | SBK / C | 1:1 / FI | S | S | PS | — | 0.30 |
| | | 29-48 | WSBK / SIC | 1:1 / FR | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 3 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 4 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 5 | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

AVAILABLE SPACE (.1945): 3 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD/FT²
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: CLARENCE COMER
COMMENTS: LINES PREFERABLY INSTALLED 28-36" TRENCH BOTTOM DEPTH

002956