IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Bridges DATE 10/8/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1/5 N., T.R. on Snow Creek Rd, on Rt before junction of SR 1904 and S.R. 1903 S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	—	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'	
			Rock or other impervious formations	some scattered Rock	

Lot Area 1 acre



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY David Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E Causey DATE 10/8/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold