ICHD - ENVIRONMENTAL HEALTH DIVISION

Statesville Office (704) 878-5305 | Mooresville Office (704) 660-3625

PERMIT # OSWP 2023-25961

SEPTIC: IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM / Repair

PIN # 4729 -- 61 -- 6617

APPLICANT/OWNER: Jesse English | APPLICANT ADDRESS: 991 Snow Creek Statesville 28625

SITE ADDRESS: 991 Snow Creek Statesville 28625 | PHONE: 334-520-4290 | ALT. PHONE

SITE DIRECTIONS: Wilkesboro Hwy - (R) Snow Creek - Lot on (R) | SAP CONTROLLED: ☐ YES ☐ NO

SUBDIVISION: | SECTION: — | LOT #: — | LOT AREA: 1.386 | DESIGN FLOW: Ex. | L.T.A.R.: Ex.


Septic Tank	1000 (gal)	STB	760	Date	5-23-2023	☐ New System	☑ Repair	☐ Expansion	System Type: I II III IV V VI
Pump Tank	(gal)	PT		Date		System Description:	Ex.		
Pump Make		Model		Serial #		Repair System Description:	Tank Replacement		
# Nitrification Fields	Ex.	# Lines	Ex	Linear Ft	Ex	Maintenance Agreement Required:	☐ YES	☑ NO	
Trench Width	Ex	Trench Bottom Depth(Low side)	Ex	Gravel Depth	Ex.		☑ GRAVITY	☐ PRESSURE	

☑ Residence	No. Bedrooms	Ex	**Water Supply**
☐ Business	No. Persons	Ex	☑ Private
☐ Other	No. Employees		☐ Public
☐ Slab	☑ Crawl Space		☐ Community
☐ Basement w/plumbing	☐ Basement w/o plumbing		

Comments / Conditions: Pump, crush, & fill new tank. Remove if needed. Replace D-Box. Keep 50' off well

System functioning properly at time of inspection

INITIAL SITE SKETCH




AS BUILT SKETCH

FOR SEPTIC FINAL INSPECTION CALL: 704-664-3703 between 8am-9am the day the inspection is needed. Be sure to speak with an inspector to confirm your time.

* Option 1 - 5' off side of house, somewhat in same tank hole

* Option 2 - 5' off back of house



Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat* valid without expiration. ☑ **IMPROVEMENT PERMIT** *with site plan* valid for 60 mos. ☑ **AUTHORIZATION TO CONSTRUCT** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: online | Date: 5/24/23 | Installed by: LENTZ WASTEWATER

IMPROVEMENT PERMIT by: Sydney Howard | Date: 5/26/23 | OPERATION PERMIT by: Burnett C. White | Date: 6-13-2023

AUTHORIZATION TO CONSTRUCT by: Sydney Howard | Date: 5/26/23 | Existing System Inspected by: | Date:

FOR SEPTIC FINAL INSPECTION: CALL 704-664-3703 between 8am-9am the day the inspection is needed.

Item	Date	Initials
Drain Lines Checked		
Tanks Checked		
Pressure Manifold or Valve Box Checked		
Pressure Head Set		
Electrical Checked		
Floats Set		
Alarm Checked		
Maintenance Contract Needed? Y / N		
Comments:		

Repairs Only	
	State Code
Failing System Code	
Type of Distribution	G or P
Type of Failure/Malfunction	
Primary Cause of Failure/Malfunction	
Age of System? _____	
Initial or Repair? _____	

PERMIT SNAPSHOT REPORT OSWP-2023-25961 FOR IREDELL COUNTY

Permit Type: Environmental Health OSWP
Work Class: EH Septic Improvement Permit Repair
Status: PRIORITY PERMIT
Valuation: $0.00
Description: Tank lid is cracked.

Project:
District: Iredell County
Square Feet: 0.00
Assigned To: Holland, Sydney

App Date: 05/22/2023
Exp Date: NOT AVAILABLE
Completed: NOT COMPLETED
Approval Expire Date:

Parcel: 4729616617.000 Main

Address: 991 Snow Creek Rd Main
Statesville, NC 28625

Zone: R-20(Suburban Residential District)
RA(Residential Agricultural District)

Property Owner	Applicant/Authorized Agent
Jesse English	Jesse English
991 Snow Ceek Rd.	991 Snow Ceek Rd.
Statesville, NC 28625	Statesville, NC 28625

Permit Custom Fields


How is your site plan being submitted	Custom Site Plan	Does the site contain any jurisdictional wetlands	No	Non-domestic Sewage Generated	No
Other Public Agency	No	What are the proposed structures	Other Addition/Structure	Maximum Number of Bedrooms	4
Number of Occupants	4	Foundation Type	Crawl Space Foundation	Water Supply	Existing Well, Other Public Water
Desired Septic System Type	Conventional (most common)	If other septic system type, please explain		If existing, Year existing system installed	1979
Additional Unique Setbacks Apply	No				

Attachment File Name	Added On	Added By	Attachment Group	Notes
Signature_Jesse_English_5/22/2023.jpg	05/22/2023 16:24	English, Jesse		Uploaded via CSS
Owner Authorization_v1.jpg	05/24/2023 8:13	Nebel, Barbara	Available Online	Authorize to Act as Agent
Septic Site Plan_v1.jpg	05/24/2023 8:13	Nebel, Barbara	Available Online	Site Plan

Invoice No.	Fee	Fee Amount	Amount Paid
NOT INVOICED	Existing System Septic Repair Permit	$150.00	$0.00
	Total for Invoice NOT INVOICED	$150.00	$0.00
	Grand Total for Permit	**$150.00**	**$0.00**

Workflow Step / Action Name	Action Type	Start Date	End Date
Application Completeness Check v.1		05/24/2023 8:13	05/24/2023 8:13
Confirm application complete v.1	Generic Action		05/24/2023 8:13
~~Zoning Review v.1~~			05/24/2023 8:13
~~Floodplain Admin Overview v.1~~	Task		05/24/2023 8:13
~~Iredell County Zoning Approval v.1~~	Task		05/24/2023 8:13
~~Issue Invoice v.1~~	Generic Action		05/24/2023 8:13
~~Fees Paid v.1~~	Generic Action		05/24/2023 8:13
Assign v.1			
Case Assigned v.1	Generic Action		
Lot Readiness Verification v.1			
OSWP Septic Preliminary Site Visit v.1	Inspection		
OSWP Site Evaluation v.1	Inspection		
Permit Ready v.1			
Issue Permit v.1			

Issue Invoice v.1	Generic Action
Fees Paid v.1	Generic Action
Issue Permit v.1	Generic Action
Environment Health Inspections v.1	
Operation Permit Inspection v.1	Inspection



Tax Map Information

• PIN	4729616617.000
• Address	991 SNOW CREEK RD
• Account #	Acct 80088279
• Tax Owner	ENGLISH JESSE
• Mailing Address	991 SNOW CREEK RD
•	STATESVILLE, NC 28625
• GIS Owner	ENGLISH JESSE+MELISSA
• Deed Info	2879 / 1483 - CD - 20211214
• Tax Acres	1.386 AC
• Lot #	
• Description	SLOAN SR1904
• Zoning	RA
• Old Parcel #	0914G00000A017D
• Bldg Value	$239,900
• OBXF Value	$2,970
• Land Value	$29,440
• Total Value	$272,310
• Defer Value	$0
• Tax Districts	-ALLCNTY FIRE- -


IREDELL COUNTY, NC

MAP FOR REFERENCE ONLY
NOT A LEGAL DOCUMENT

Iredell County, North Carolina makes no claims and no warranties, expressed or implied, concerning the validity or accuracy of the GIS data presented on this map.

Geometry updated 05/10/2023
Data updated 05/10/2023

Print map scale is approximate. Critical layout or measurement activities should not be done using this resource.



IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Bridges DATE 10/8/79 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION 115N, I-8 on Sam Couch Rd, on Rt before junction of SR 1904 and S.C 1903

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash Machine	Yes (✓)	No ( )	
Soil Suitable	Yes ( )	No ( )	

Lot Area 1 acre


Character & Porosity of Soil Red clay loam

Percolation Rate —

Topography 4-6%

Depth to Water Table n/k

Rock or other impervious formations encountered Rock



Size of Tank 1250 Gals.

Nitrification Field

No. of Lines 2

Sq. Ft. 250 Linear Ft. 250

Depth of Stone in Lines 16

Water Supply: Individual (✓)

Public ( )

Installed by Hyde Bros

IMPROVEMENTS PERMIT BY _____