DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED: _____

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Randy Bridges OWNER: AGENT: PHONE:

ADDRESS: APPLICATION DATE: DATE EVALUATED:

PROPOSED FACILITY:

PROPERTY SIZE:

LOCATION OF SITE: Cornor Ford Farm Rd + Snow Creek Rd

WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 10%	0 to 6	L GR		PS	PS	PS	PS	.3
		6 to 36	C SBK	S EAP Fr					
		36 to 42	clay sap						
		42"+	sap						
2	Linear 4%	0 to 6	L GR		PS	PS	PS	PS	.3
		6 to 36	C SBK	S EAP Fr. chroma 2 36"+					
		36 to 48	C ABK to massive	EAP very Fi					
3	Linear 4%	0 to 6	L GR		PS	PS	PS	PS	.3
		6 to 48	C SBK	S EAP Fr					
4	Foot Slope 7%	0 to 18	C ABK	SEAP Fr	U Chroma 2	U	U	U	
		18"+	C ABK	EAP Fi					
5									

AVAILABLE SPACE (.1945): Yes SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: L.C. Moore OTHER(S) PRESENT: Randy Bridges

COMMENTS:

00319