IREDELL COUNTY HEALTH DEPARTMENT

704-908-3794
336-751-3794

CF

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

called 6-27-07 @ 9:11

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 38745 PIN# 4730631002 DATE 3-26-07

OWNER OR APPLICANT Lavery Homes PHONE: Business 704/1487 Home

ADDRESS BW 3416 Mooresville NC 28117

LOCATION State Park Dr on left past Morrison Transmission

SUBDIVISION The Park BLOCK / SECTION LOT 2 LOT AREA 1.0 SITE CLASS. DESIGN FLOW 660 L.T.A.R. .3

Septic Tank: 1500 Gallons; STB 338 Date 1-19-07
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields Square Feet 2000 Linear Feet 500
No Lines 5 Trench Width 36" Max Trench Bottom Depth 36"

☐ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI
System Description: 25% Gravity
Repair System Description: 100% Rule Panel
Maintenance Agreement Required: ☐ Yes ☑ No
Gravel Depth ☐ Gravity ☑ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:
Must be on Certified
Maintain all setbacks

Comments:/Conditions: POLYFLOW FILTERS RISERS
Need well abandonment paperwork for AC to be issued

INITIAL SITE SKETCH

(See ATTACHED drawing for details)

AS BUILT SKETCH

Must be Certified
SYSTEM 10' + OFF MARKED P/L'S
WELL IS 100' FROM TANK
30' FALL FROM TANK TO 1ST LOT. DOUBLE WIDTHS REQUIRED

The proposed inground pool addition does not appear to impact the existing septic system.
**NOTE:

R.S.
Date: 5-11-10
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Jean ap Lavery date 3-23-07
Improvement Permit by: date 3-26-07
Authorization to Construct by: date 4-5-07

Installed by: R+H OF LAKE NORMAN, INC
Operation Permit by: date 3-4-08
Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK