DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 619 PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot [illegible], Parkwood S/D PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1 (#12)		0 - 5	w, sbk, SCL	Fr, SS, SP (Br)					PS
		5 - 27	w, sbk, C	Fr, SS, SP (Red)					
		27 - 50	w, sbk, CL	Fr, SS, SP (Red)	c - SAP	Inc Lw,			0,30
2		0-6	gr SL	fr SSP					.3
		6-36	wk sbk C	fr SSSP SAP					
		36-55	wk sbk C	fr SSSP	common - many mod SAP				
3	4%	0-12	[illegible] C	fr SSSP					.37 12+
		12-57	wk sbk cl + SAP	fr SSSP					
4		0-5	wk sbk bm SCL	fr SSSP					.3
		5-19	wk sbk mod C	fr SSSP					
		19-29	wk sbk mod CL	fr SSSP	many SAP mod				
		29-51	moderate LSAP	fr SSSP	few prominent				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____