10:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (a) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# ~~140179~~ 16660 PIN# ~~4730-10-9265.621~~ 4730-20-8124.000 DATE 6-8-07

OWNER OR APPLICANT Falls Cove Dev. LLC / WYNSOR Homes PHONE: Business _____ Home _____

ADDRESS 2215 Brawley School Rd Mooresville NC 28115

LOCATION State Park Rd TL Morrison Farm TL Silver Falls TL #179 Timber Lake Dr. 4th on left past Silver Falls

SUBDIVISION Parkwood @ Falls Cove BLOCK / SECTION 6 LOT 621 LOT AREA 44046 ft² SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .25 gpd/ft²

Septic Tank: 1500 ± Gallons: STB 444 Date 9-30-11

Pump Tank: 1500 ± Gallons: PT 477 Date 10-30-11

Pump Make: Goulds Model WE0512HHU Serial No.

Nitrification Field: No Fields 1 Square Feet 1920 Linear Feet 320

No Lines 4 Trench Width 36" ± Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees ____

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

± per plan specs

Fill all gullies

Comments:/Conditions:

INITIAL SITE SKETCH

See plan from SY ME

AS BUILT SKETCH

GOULDS PUMPS

WE0512HHU

SUBMERSIBLE PUMP

1/2HP 1/60/230 3.87" 7.3MA

ITT *Engineered for life*

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 06/25/07

Improvement Permit by: Judy Merrill date 6-8-07

Authorization to Construct by: _____ date 5-13-11

Installed by: Luther Myers Septic Tank

Operation Permit by: _____ date 12-27-11

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK