DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 16468
PROPERTY RECORDED: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jim Leonard OWNER: ✓ AGENT: ___ PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6-9-93
PROPOSED FACILITY: House
PROPERTY SIZE: ___
LOCATION OF SITE: Lockhard Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1945 LANDSCP POS (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 3-6 %	0"-2"	scl / vfr, cr	1:1 / vfr	PS	NA	PS	42"-↑	.30
		2"-30"	c / sbk	1:1 / fr					
		30"-42"	sc / sbk						
		42"-↑	saprolite						
2	L 3-6 %	0"-2"	scl / cr	1:1 / vfr	PS.	NA	PS	NA	.30
		2"-30"	c / sbk	1:1 / fr					
		30"-48"	sc / sbk						
3									
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .30 gpd / ft 2
EVALUATED BY: Michael Q. Dennis OTHER(S) PRESENT: ___
COMMENTS: Install system shallow (no deeper than 30" to trench bottom)